

DEPARTMENT OF CIVIL ENGINEERING

INSTITUTE OF ENGINEERING & TECHNOLOGY

An Autonomous Constituent Institute of Dr. APJ Abdul Kalam Technical University Uttar Pradesh SITAPUR ROAD, LUCKNOW (U.P.), INDIA PIN-226021

Dr N.B. SINGH Professor E mail: nbs.iet@gmail.com nbsingh@ietlucknow.ac.in

Mobile: +91 9415166024

Ref: IET/CE/NBS/2021/ 19

Date: 16/10/2021

To.

M/s GREENBERRY WORLD SCHOOL

Miranpur Pinwat,

59, Daroga Khera,

Kanpur Road,

Lucknow

THIRD PARTY INSPECTION REPORT

In reference to your letter number NIL dated 08/10/2021 regarding checking of stability of Greenberry World School building.

The inspection of administrative building & primary building in Greenberry World School Lucknow (U.P) was conducted on dated 13/10/2021 in presence of officials from Greenberry World School.

Observations:

- 1. Rebound hammer test has been carried out to assess the stability of the existing administrative building & primary building at Greenberry World School.
- Compressive strength of the structural components (Beams, Columns etc.) of administrative building & primary building was found to be more than 25 N/mm² which is as per the drawings provided by the client.

Overall construction quality was found satisfactory and structure is found safe as per the codes of BIS.

Abhishek Mishra

M.Tech (Structures)

Assistant Professor

C.E.D., I.E.T. Lucknow

Dr. N. B. Singh

Professor,

Civil Engg. Deptt.

I.E.T. Lucknow